

TITLE 3: FIRE PREVENTION CODE

CHAPTER 1. GENERAL 1

 § 1. Purpose and Scope 1

 § 2. Applicability 1

 § 3. Administration 2

CHAPTER 2. FIRE SAFETY PERMITS 3

 § 1. Permits Required 3

 § 2. Types of Permits 3

 § 3. Other Required Notifications or Approvals 5

CHAPTER 3. INSPECTIONS 6

 § 1. General 6

 § 2. Permit Specific Inspections 6

 § 3. Liquor Control Inspections 6

 § 4. Construction Inspections 6

 § 5. Fire Control and Fire Alarm Acceptance Testing..... 7

 § 6. Certificate of Completion Inspections 7

 § 7. Annual Inspections 7

 § 8. Complaints 8

CHAPTER 4. CODES ADOPTED BY REFERENCE 8

 § 1. New construction, renovation, or change of use and new buildings..... 8

 § 2. Existing buildings/occupancies 8

 § 3. Fire Prevention and other adopted life safety codes and references 8

 § 4. Equivalency 9

CHAPTER 5. MPTN SUPPLEMENT 9

 § 1. General 9

 § 2. Amendments to the 2015 International Fire Code 12

 § 3. Amendments to the 2015 Life Safety Code (NFPA 101) 12

 § 4. Amendments to the 2015 Uniform Fire Code (NFPA 1) 12

History

| <u>Revision</u> | <u>Authorizing Actions</u> | <u>Description</u> |
|-----------------|----------------------------|---|
| 20-Jun-14 | LU-14-079 | Codified as 2 L.U.R. pursuant to TCR052914-04 of 10 |
| 23-Nov-16 | LU-17-501 | Adopted Interim Code Adoption, Technical Provisions |
| 01-Oct-18 | LU-18-503 | Revised with Updated Codes |

TITLE 3. FIRE PREVENTION CODE

CHAPTER 1. GENERAL

§ 1. Purpose and Scope

a. The purpose of this code is to establish the minimum requirements necessary to safeguard the public health, safety and general welfare.

b. The provisions of this code shall apply to the construction, alteration, movement, enlargement, replacement, repair, equipment, use and occupancy, location, maintenance, removal, demolition, and occupancy of every building or structure or any appurtenances connected or attached to such buildings or structures in Mashantucket, and

§ 2. Applicability

a. General

- (1) This Title, to be known as the Mashantucket Fire Prevention Code, has been adopted by the Mashantucket Pequot Land Use Commission for regulating and governing the conditions and maintenance of all property, buildings and structures; by providing the standards for facilities, supplied utilities and other physical things and conditions essential to ensure that structures are safe, sanitary and fit for occupation and use; and the condemnation of buildings and structures unfit for human occupancy or use.
- (2) This Mashantucket Fire Prevention Code shall apply to all persons and places in Mashantucket. All must comply with the applicable prohibitions and fire and life safety requirements.
- (3) Chapter 4 identifies those model codes, published by the National Fire Protection Association (NFPA), which have been adopted by reference as part of this Title. Chapter 5 contains the MPTN Supplement to those adopted model codes. Where there is a conflict between a provision specified within the MPTN Supplement (Ch. 5) and that specified within one of the adopted NFPA Codes (Ch. 4), the provision as stated in the MPTN Supplement shall govern.
- (4) Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern.
- (5) In the event that any part or provision of this code is held to be illegal or void, this shall not have the effect of making void or illegal any of the other parts or provisions.

b. Existing structures

The legal occupancy of any structure existing on the date of adoption of this code shall be permitted to continue without change, except as is specifically covered in this Title or the MPTN Building Code, or as is deemed necessary by the Land Use Commission for the general safety and welfare of the occupants and the public.

- (1) Alterations to any building or structure shall comply with the requirements of this Code for new construction. Alterations shall be such that the existing building or structure is no less conforming to the provisions of the Code than the existing building or structure was prior to the alteration.

- (2) A change in use usually changes the applicability of code requirements and as such, will subject the entire area relevant to the change in use to review for compliance with this Code. However, the Fire Marshal may permit a change in use without full compliance if the new use is less hazardous than the existing use based on life and fire risk.
- (3) Any deficiency discovered must be rendered no less conforming to the provisions of the Code that was enforced at the time the existing building or structure was originally constructed.

c. Permits Required

(1) Land Use Permit

Any person who requires a permit pursuant to 14 M.P.T.L, the Land Use Law, must first obtain a Permit from the MPTN Land Use Commission prior to issuance of any permit required by the Fire Marshal.

(2) Fire Safety Permits

Persons and businesses that conduct or supervise the activities regulated by this Code may also be required to obtain permits and certificates that authorize them to engage in those activities. Chapter 2 of this Title describes those specific Fire Safety Permits required by any person who intends to engage in a covered activity.

d. Inspections Required

- (1) All permitted activities must be inspected by the Fire Marshal to ensure compliance with this Code prior to occupancy or use.
- (2) Other specific inspections shall be conducted as specified within Chapter 3 of this Title.

§ 3. Administration

a. Fire Marshal

The Fire Marshal is the Land Use Commissioner who represents the MPTN Fire Department and is appointed as specified within 1 L.U.R. ch. 1, §3a.(4).

- (1) The Fire Marshal shall have the authority to render interpretations of this Code.
- (2) The Fire Marshal shall enforce the provisions of this Code as specified within MPTN Land Use Law (14 M.P.T.L).
- (3) The Fire Marshal shall keep official records of applications received, permits and certificates issued, reports of inspections, and notices and orders issued. Such records shall be retained in the official records for the period specified by the MPTN record retention policy.
- (4) The Fire Marshal, while acting in good faith and without malice in the discharge of the duties required by this code or other pertinent law or ordinance, shall not thereby be rendered liable personally and is hereby relieved from personal liability for any damage occurring to persons or property as a result of any act or by reason of an act or omission in the discharge of official duties. Any suit instituted against an officer or employee because of an act performed by that officer or employee in the lawful discharge of duties and under the provisions of this code shall be defended by legal representative of MPTN until the final termination of the proceedings.

(5) Right of Entry

In addition to the authority established within 14 M.P.T.L. Ch. 9, § 1b, where the Fire Marshal has reasonable cause to believe that there exists, in a structure or upon a premises, a condition which is contrary to or in violation of this code which makes the structure or premises unsafe, dangerous or hazardous, the Fire Marshal is authorized to enter the structure or premises at reasonable times to inspect or to perform the duties imposed by this code, provided that if such structure or premises is occupied that credentials be presented to the occupant and entry requested. If such structure or premises is unoccupied, the Fire Marshal shall first make a reasonable effort to locate the owner or other person having charge or control of the structure or premises and request entry. If entry is refused, the Fire Marshal shall have recourse to the remedies provided by law to secure entry.

(6) Require Testing

- (a) Whenever there is insufficient evidence of compliance with the provisions of this code, or evidence that a material or method does not conform to the requirements of this code, or in order to substantiate claims for alternative materials or methods, the Fire Marshal shall have the authority to require tests as evidence of compliance to be made at the expense of the owner. Test methods shall be as specified in this code or by other recognized test standards. In the absence of recognized and accepted test methods, the Fire Marshal shall approve the testing procedures.
- (b) Tests shall be performed by an approved agency. Reports of such tests shall be retained by the Fire Marshal for the period specified by the MPTN record retention policy.

b. Fire Protection Inspectors

The Fire Marshal, from time to time, may utilize staff or contract other inspectors, plan examiners or other technical contractors to assist with the duties of Fire Marshal. Such individuals shall have powers as delegated by the MPTN Fire Chief.

CHAPTER 2. FIRE SAFETY PERMITS

§ 1. Permits Required

a. It is the responsibility of the owner or agent to ensure that each contractor, prior to commencing work on his permitted activity, applies for and is issued all applicable Fire Safety Permits. Failure of a Permittee's contractors to obtain the applicable permits prior to commencing work may result in Enforcement Action against the Permittee by the MPTN Land Use Commission.

b. Commencement of work without a properly issued Permit will result in the issuance of a Citation with penalty pursuant to 1 L.U.R. Ch 8, as authorized by 14 M.P.T.L. Ch. 9, §2a.

§ 2. Types of Permits

a. Hot Work Permits

A Hot Work Permit is required for any temporary operation involving open flames or producing heat and/or sparks. Those include but are not limited to: brazing, cutting, grinding, soldering, torch cutting or torch-applied roofing and welding.

- (1) Prior to beginning any hot work, contractors shall request a permit from the Fire Alarm Center by calling 860 312-4397.
 - (2) Upon request the MPTN Fire Department will conduct an inspection of the job site. The inspection shall include fire extinguishers, work to be performed and fire watch.
 - (a) Extinguishers must be full, pinned and sealed, and have a current inspection tag.
 - (b) Hot work equipment must be in good operating order.
 - (c) The area within thirty-five (35) feet must be clear of and combustibles, flammable liquids, dusts, or explosive atmospheres.
 - (3) The contractor shall notify the Fire Alarm Center upon completion of work. and be present at the job site to sign-off that the work has been completed and that the job site is fire safe.
 - (4) The MPTN Fire Department will complete a final walk thru of the job site.
 - (a) The contractor shall be present at this walk thru,
 - (b) sign the permit verifying that work is completed and the job site is fire safe, and
 - (c) return the permit to MPTN Fire personnel upon their final walk thru.
- b. Blasting Permits
- (1) A Blasting Permit is required for the transport and use of explosives.
 - (a) Transport of explosives is restricted to the most direct route to and from an active job site.
 - (b) No vehicle transporting any quantity of explosives shall be left unattended at any time, and when attended, the attendant must be a licensed blaster.
 - (c) Permits shall only be issued to blasters licensed by the State of Connecticut.
 - (d) Blasters shall call the Fire Department Routine Dispatch Number (860 396-6662) daily to report blasting activity that day, before operations begin.
 - (2) Applications for Blasting Permits shall be submitted on forms provided by the MPTN Fire Marshal's Office.
- c. Event/Display Permits
- (1) Special events that include erection of a tent, stage, bandshell, trailer, portable building, grandstand, bleachers or placement of portable toilets are considered Land Use Activities and require a permit from the Land Use Commission pursuant to 14 M.P.T.L.
 - (2) Any other event or display, not requiring a Land Use Permit, requires an Event/Display Permit from the MPTN Fire & Emergency Services.
 - (3) Applications for Event/Display Permits shall be submitted on forms provided by the MPTN Fire Marshal's Office.
- d. Display Special Effect Permits
- (1) Permits are required for all fireworks displays or other pyrotechnic effects.
 - (2) Applications for a Permit to Display Special Effects shall be submitted on forms provided by the MPTN Fire Marshal's Office.
- e. Vehicle Display
- (1) The display of a vehicle, motorcycle, boat, etc. in a building, tent, canopy or public area requires a permit.
 - (2) Applications for a Vehicle Display Permit shall be submitted on forms provided by the MPTN Fire Marshal's Office.

f. Temporary Storage

- (1) Temporary Storage of any materials outside of a designated storage area requires a permit.
- (2) Exterior placement and use of storage containers or temporary designation of a storage yard (e.g. Conex and lay-down area) requires a permit.
- (3) Applications for a Temporary Storage Permit shall be submitted on forms provided by the Fire Marshal's Office.
- (4) Issued Permits must be posted at the location of storage at all times.

g. Open Burning

- (1) Applications for open burning shall be submitted on forms provided by the MPTN Fire Marshal's Office.
- (2) Notification shall be provided to Fire Department Dispatch (860 396-6662) prior to and at the conclusion of the burn.
 - (a) Fires shall not be commenced prior to 8:00 am, and
 - (b) must be completely extinguished, by wetting down to ensure that there will be no rekindling of fire, by 5:00 pm.
- (3) The fire must be maintained such as to minimize smoke production. Fires shall not contain fallen leaves garbage, trash, plastics, rubber, painted or chemically treated materials, or construction/demolition debris.
- (4) Permits, when issued, shall be conditional upon conditions at the time of the burn. No burn shall be commenced:
 - (a) when the Forest Fire Danger is rated high, very high or extreme;
http://www.ct.gov/deep/cwp/view.asp?a=2222&q=320740&deepNav_GID=1631
 - (b) when the Air Quality Index (AQI) is forecasted to be 75 or higher;
<http://www.ct.gov/deep/cwp/view.asp?a=2222&q=320646>
 - (c) outside the hours of 8:00 am and 5:00 pm;
 - (d) when wind speed is less than 5 miles per hour or greater than 15 miles per hour; and
 - (e) skies are overcast.
- (5) Fire control equipment (i.e. brooms, rakes, garden hose, water filled buckets, etc.) shall be kept at the burn site until the fire is completely extinguished.
- (6) The burn shall be supervised at all times and a copy of the Permit kept at the burn site and readily available to the authority having jurisdiction.

§ 3. Other Required Notifications or Approvals

a. Crane Permits

The Fire Marshal must review and approve all crane lift plans.

b. Liquor Control

The Fire Marshal shall only sign-off on Liquor Control Permits following successful passage of inspection.

c. Fire Control and Fire Alarm Systems

Before commencing any and all work on Fire Alarm or Sprinkler Systems the contractor shall contact the Fire Marshal to schedule a meeting to discuss requirements, approved plans and related matters.

- (1) Electrical contractors for fire alarm systems shall request a site walk down from the Fire Department prior to the start of work on any system. This is to allow for the review of device compatibility, programming, modification to existing wiring and other related issues.
- (2) Any and all questions or issues relative to Fire Code compliance shall be forwarded to the Fire Marshal; this includes sprinkler and fire alarm systems.
- (3) Contractors performing any work shall adhere to the project specification documentation supplied with plans or drawings which must be reviewed and approved by the Fire Marshal.
- (4) Failure to schedule a pre-construction meeting before commencing construction may result in the issuance of a citation.

CHAPTER 3. INSPECTIONS

§ 1. General

The Fire Marshal is responsible for compliance with this Fire Prevention Code. Therefore, any area visited by the Fire Marshal during the normal course of his duties is subject to his inspection. Deficiencies found to exist, shall be Cited by the Fire Marshal, pursuant 1 L.U.R. Ch 8 (as authorized by 14 M.P.T.L. Ch. 9, §2a), in writing to the owner, lessee, occupant, or person in control of such building, structure, or place to remedy such condition.

§ 2. Permit Specific Inspections

Typically, an inspection is completed prior to the Fire Marshal issuing a permit. However, all permitted activities are subject to unannounced inspection at any time during the permitted activity. Deficiencies found to exist, shall be Cited by the Fire Marshal, pursuant 1 L.U.R. Ch 8 (as authorized by 14 M.P.T.L. Ch. 9, §2a), in writing to the Permittee.

§ 3. Liquor Control Inspections

Applications for a State Liquor Permit require sign-off by the Fire Marshal. Applicants must contact the Fire Marshal's office to schedule an inspection for this purpose.

§ 4. Construction Inspections

- a. The Fire Marshal will inspect any construction activity or installation to ensure compliance with this code.
- b. Whenever any installation subject to inspection, testing and/or approval in accordance with this code, is covered or concealed without having first been inspected, tested and/or approved, the Fire Marshal may require that such work be exposed for inspection.
- c. General Housekeeping
 - (1) In addition to specific code requirements the Fire Marshal shall enforce the following general housekeeping requirements when inspecting construction activities.
 - (a) Combustibles shall be maintained to a minimum in the work area. All trash, packing materials and other excessive combustibles shall be removed at the end of the work shift.

When practical, all unpacking should be done outside of the facility, or have combustible packing materials at the work location removed immediately.

- (b) Contractors shall bring inside the work area ONLY the minimum amounts of flammable/combustible liquids, cutting/welding gases and paints or other solvents for that work shift. These shall be stored in approved containers and must be removed to a designated storage area outside of the building at the end of each shift.
 - (c) Contractors, and those in their employ, shall observe the smoking policy of all MPTN facilities.
 - (d) Contractors are responsible to provide their own fire extinguishers for the job site as required by the Hot Work Permit. Fire extinguishers mounted on the walls are to be used only in an emergency as a backup by the Fire Watch.
- (2) Anyone found in violation of any rules will be subject to disciplinary action, up to and including fines and/or removal from the job site.
- d. An emergency management evacuation and notification plan may be required for some job sites.

§ 5. Fire Control and Fire Alarm Acceptance Testing

If required, Acceptance Testing for installation or modifications made to a Fire Control or Fire Alarm System shall be witnessed by the Fire Marshal.

- (1) All work shall be completed, systems ready and pre-tested prior to the arrival of the inspector.
- (2) Failure to pre-test may result in a cancellation or inspection/test failure.

§ 6. Certificate of Completion Inspections

The Land Use Commission shall not issue a Certificate of Completion and a Permitted Activity shall not be occupied, used or operated without a final inspection by the Fire Marshal.

- (1) A temporary Certificate may be issued if the Fire Marshal and Building Official have confirmed that there are no outstanding life safety concerns.
- (2) A final Certificate can only be issued when the Fire Marshal and Building Official have completed their final inspections and found there to be no outstanding issues.

§ 7. Annual Inspections

a. The Fire Marshal shall make, or cause to be made, inspections with sufficient frequency to secure efficient supervision of all buildings, structures, and places used either for commercial purposes or occupied or frequented by large numbers of people, and of all schools, institutions, theaters, multiple dwellings, or places of assembly to determine:

- (1) whether there exists any fire hazards in corridors, stairways, fire escapes, and their approaches with regard to obstructions, in the disposition, quantity, arrangement, and protection of stock and combustible material, in the disposal of waste materials, or in heating devices and ovens;
- (2) whether there are solids, liquids, or gasses which may be flammable, poisonous, reactive, or explosive, alone or in combination, or under fire conditions; and
- (3) that hazardous machinery and appliances are protected with regard to safety from fire; and to ascertain whether the provisions of this Code are being effectively carried out.

b. Deficiencies found to exist, shall be Cited by the Fire Marshal, pursuant 1 L.U.R. Ch 8 (as authorized by 14 M.P.T.L. Ch. 9, §2a), in writing to the owner, lessee, occupant, or person in control of such building, structure, or place to remedy such condition.

§ 8. Complaints

a. The Fire Marshal shall make or cause to be made an inspection of any building, structure, or place within a reasonable time after any person complains that:

- (1) any provision of this Code is being violated, or
- (2) that combustible materials are kept in such building, structure, or place in such a manner as to cause a fire or increase the intensity or spread of fire, or
- (3) that doors, stairways, corridors, exits, fire escapes, or means of ingress or egress in any factory, workshop, place of amusement, education, employment, habitation, or recreation facility is obstructed or in an unsafe condition, or
- (4) that any exit door or exit is kept locked or fastened during the time such places are occupied or frequented by employees or by the public, or
- (5) that any such building, structure, or place is occupied or crowded beyond the capacity of its exits, or
- (6) that heating appliances, apparatus, or devices in any such building or structure are insecure or dangerous, or
- (7) that any building, structure, or place is being maintained in such a manner as to be a fire menace or dangerous in case of fire or explosion.

b. If any of the above conditions is found to exist, the Fire Marshal may issue a Citation, pursuant 1 L.U.R. Ch 8 (as authorized by 14 M.P.T.L. Ch. 9, §2a), in writing to the owner, lessee, occupant, or person in control of such building, structure, or place to remedy such condition.

CHAPTER 4. CODES ADOPTED BY REFERENCE

As authorized by 14 M.P.T.L. Ch. 4, the MPTN Land Use Commission has adopted the model codes specified within this chapter, by reference; except as may be amended, altered or deleted within Chapter 5 of this Title, the MPTN Supplement, or as may be superseded in the future by amendment to this Chapter.

§ 1. New construction, renovation, or change of use and new buildings.

International Fire Code of the International Code Council, Inc., 2015 edition.

§ 2. Existing buildings/occupancies.

NFPA 101, Life Safety Code 2015 edition.

§ 3. Fire Prevention and other adopted life safety codes and references.

NFPA 1, Uniform Fire Code 2015 edition

§ 4. Equivalency

a. In general, provisions within the 2016 Connecticut Fire Safety Code, only to the extent that they add, amend or otherwise specify changes to the model code provisions adopted within this title, will be considered acceptable as an alternative or an equivalent method of compliance provided such alternatives are acceptable upon approval by the Building Official and Fire Marshal.

b. When considering whether or not to raise an objection the Building Official and Fire Marshal shall ensure compliance with the intent of the following:

- (1) Section 14 of the Tribal-State Compact that requires tribal ordinances and regulations, governing health and safety standards applicable to gaming facilities, be no less rigorous than standards generally imposed by the laws and regulations of the State relating to public facilities with regard to building, sanitary, and health standards and fire safety; and,
- (2) Tribal Council Resolution TCT102704-02 of 03 that requires the Land Use Commission, with respect to home construction, to apply regulatory interpretation that is consistent with the interpretation of similar building code provisions in New London County, Connecticut.

CHAPTER 5. MPTN SUPPLEMENT

§ 1. General

a. Referenced Model Code Annotations - As used in this chapter, a referenced section or subsection preceded by bracketed annotations have the following meaning:

- (1) [Add] - indicates the addition to the adopted referenced standard.
- (2) [Amd] - indicates the substitution in the adopted referenced standard.
- (3) [Del] - indicates the deletion of this section or subsection from the adopted referenced standard.

b. Referenced Code and Standards.

- (1) Any reference to a model code adopted within chapter 4, shall mean as amended by this chapter.
- (2) The codes and standards referenced within the body of the model codes adopted shall be considered part of the code requirements to the prescribed extent of each such reference, except that:
 - (a) references to the International Fuel Gas Code shall be considered references to requirements of NFPA 54, National Fuel Gas Code, NFPA 56, Standard for Fire and Explosion Prevention During Cleaning and Purging of Flammable Gas Piping Systems and NFPA 58, Liquefied Petroleum Gas Code;
 - (b) references to the following NFPA standards shall be considered references to the version noted:

NFPA 2 Hydrogen Technologies Code, 2011 Ed.

NFPA 10 Standard for Portable Fire Extinguishers, 2013 Ed.

NFPA 12 Standard on Carbon Dioxide Extinguishing Systems, 2011 Ed.

NFPA 13 Standard for the Installation of Sprinkler Systems, 2013 Ed.

NFPA 13D Standard for the Installation of Sprinkler Systems in One- and Two-Family Dwellings and

| | |
|----------|--|
| | Manufactured Homes, 2013 Ed. |
| NFPA 13R | Standard for the Installation of Sprinkler Systems in Low-Rise Residential Occupancies, 2013 Ed. |
| NFPA 14 | Standard for the Installation of Standpipe and Hose Systems, 2013 Ed. |
| NFPA 15 | Standard for Water Spray Fixed Systems for Fire Protection, 2012 Ed. |
| NFPA 16 | Standard for the Installation of Foam-Water Sprinkler and Foam-Water Spray Systems, 2015 Ed. |
| NFPA 17 | Standard for Dry Chemical Extinguishing Systems, 2013 Ed. |
| NFPA 17A | Standard for Wet Chemical Extinguishing Systems, 2013 Ed. |
| NFPA 20 | Standard for the Installation of Stationary Pumps for Fire Protection, 2013 Ed. |
| NFPA 22 | Standard for Water Tanks for Private Fire Protection, 2013 Ed. |
| NFPA 25 | Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems, 2014 Ed. |
| NFPA 30 | Flammable and Combustible Liquids Code, 2018 Ed. |
| NFPA 30A | Code for Motor Fuel Dispensing Facilities and Repair Garages, 2018 Ed. |
| NFPA 31 | Standard for the Installation of Oil-Burning Equipment, 2011 Ed. |
| NFPA 34 | Standard for Dipping and Coating Processes Using Flammable or Combustible Liquids, 2015 Ed. |
| NFPA 37 | Stationary Combustion Engines & Gas Turbines 2014 Ed |
| NFPA 51 | Standard for the Design and Installation of Oxygen-Fuel Gas Systems for Welding, Cutting, and Allied Processes, 2013 Ed. |
| NFPA 51B | Standard for Fire Prevention During Welding, Cutting, and Other Hot Work, 2014 Ed. |
| NFPA 52 | Vehicular Gaseous Fuel Systems Code, 2013 Ed. |
| NFPA 54 | National Fuel Gas Code 2015 Ed |
| NFPA 55 | Compressed Gases and Cryogenic Fluids Code, 2013 Ed. |
| NFPA 56 | Standard for Fire & Explosion Prevention During Cleaning & Purging of Flammable Gas Piping Systems, 2014 Ed |
| NFPA 58 | Liquefied Petroleum Gas Code 2011 Ed |
| NFPA 59 | Utility LP-Gas Plant Code, 2015 Ed. |
| NFPA 59A | Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG), 2013 Ed. |
| NFPA 70 | National Electrical Code® 2017 Ed |
| NFPA 72 | National Fire Alarm Code 2013 Ed |
| NFPA 75 | Standard for Protection of Information Technology Equipment, 2013 Ed. |
| NFPA 76 | Standard for the Fire Protection of Telecommunications Facilities, 2012 Ed. |
| NFPA 80 | Standard for Fire Doors and Other Opening Protectives, 2013 Ed. |
| NFPA 82 | Standard on Incinerators and Waste and Linen Handling Systems and Equipment, 2014 Ed. |
| NFPA 85 | Boiler and Combustion Systems Hazards Code, 2015 Ed. |
| NFPA 88A | Parking Structures 2015 Ed |
| NFPA 90A | Air-Conditioning and Ventilating Systems 2015 Ed |
| NFPA 90B | Warm Air Heating and Air-Conditioning Systems 2015 Ed |
| NFPA 91 | Standard for Exhaust Systems for Air Conveying of Vapors, Gases, Mists, and Noncombustible Particulate Solids, 2010 Ed. |
| NFPA 92 | Standard for Smoke Control Systems, 2015 Ed. |
| NFPA 96 | Standard on Ventilation Control and Fire Protection of Commercial Cooking Operations, 2014 |
| NFPA 99 | Health Care Facilities Code, 2015 Ed. |
| NFPA 102 | Standard for Grandstands, Folding and Telescopic Seating, Tents, and Membrane Structures, 2011 |

| | |
|-----------|---|
| NFPA 105 | Standard for Smoke Door Assemblies and Other Opening Protectives, 2013 Ed. |
| NFPA 110 | Standard for Emergency and Standby Power Systems, 2013 Ed. |
| NFPA 111 | Standard on Stored Electrical Energy Emergency and Standby Power Systems, 2013 Ed. |
| NFPA 140 | Standard on Motion Picture and Television Production Studio Soundstages, Approved Production Facilities, and Production Locations, 2013 Ed. |
| NFPA 160 | Standard for the Use of Flame Effects Before an Audience, 2011 Ed. |
| NFPA 170 | Standard for Fire Safety and Emergency Symbols, 2015 Ed. |
| NFPA 204 | Standard for Smoke and Heat Venting, 2015 Ed. |
| NFPA 211 | Standard for Chimneys, Fireplaces, Vents, and Solid Fuel-Burning Appliances, 2013 Ed. |
| NFPA 220 | Standard on Types of Building Construction, 2015 Ed. |
| NFPA 221 | Standard for High Challenge Fire Walls, Fire Walls, and Fire Barrier Walls, 2015 Ed. |
| NFPA 232 | Standard for the Protection of Records, 2012 Ed. |
| NFPA 241 | Standard for Safeguarding Construction, Alteration, and Demolition Operations, 2013 Ed. |
| NFPA 252 | Standard Methods of Fire Tests of Door Assemblies, 2012 Ed. |
| NFPA 253 | Standard Method of Test for Critical Radiant Flux of Floor Covering Systems Using a Radiant Heat Energy Source, 2015 Ed. |
| NFPA 257 | Standard on Fire Test for Window and Glass Block Assemblies, 2012 Ed. |
| NFPA 259 | Standard Test Method for Potential Heat of Building Materials, 2013 Ed. |
| NFPA 326 | Standard for Safeguarding of Tanks and Containers for Entry, Cleaning, or Repair, 2010 Ed. |
| NFPA 400 | Hazardous Materials Code, 2013 Ed. |
| NFPA 407 | Standard for Aircraft Fuel Servicing, 2012 Ed. |
| NFPA 484 | Standard for Combustible Metals, 2015 Ed. |
| NFPA 495 | Explosive Materials Code, 2013 Ed. |
| NFPA 498 | Standard for Safe Havens and Interchange Lots for Vehicles Transporting Explosives, 2013 Ed. |
| NFPA 501 | Standard on Manufactured Housing, 2013 Ed. |
| NFPA 501A | Standard for Fire Safety Criteria for Manufactured Home Installations, Sites, and Communities, 2013 Ed. |
| NFPA 601 | Standard for Security Services in Fire Loss Prevention, 2010 Ed. |
| NFPA 664 | Standard for the Prevention of Fires and Explosions in Wood Processing and Woodworking Facilities, 2012 Ed. |
| NFPA 703 | Standard for Fire Retardant-Treated Wood and Fire Retardant Coatings for Building Materials, 2015 Ed. |
| NFPA 704 | Standard System for the Identification of the Hazards of Materials for Emergency Response, 2012 |
| NFPA 720 | Standard for the Installation of Carbon Monoxide Detection and Warning Equipment, 2015 |
| NFPA 750 | Standard on Water Mist Fire Protection Systems, 2014 Ed. |
| NFPA 801 | Standard for Fire Protection for Facilities Handling Radioactive Materials, 2013 Ed. |
| NFPA 909 | Code for the Protection of Cultural Resource Properties – Museums, Libraries, and Places of Worship, 2013 Ed. |
| NFPA 914 | Code for Fire Protection of Historic Structures, 2010 Ed. |
| NFPA 1124 | Standard for the Manufacture, Transportation, Storage, and Retail Sales of Fireworks and Pyrotechnic Articles, 2006 Ed. |
| NFPA 1126 | Standard for the Use of Pyrotechnics Before a Proximate Audience, 2011 Ed. |
| NFPA 1142 | Standard on Water Supplies for Suburban and Rural Fire Fighting, 2012 Ed. |
| NFPA 1194 | Standard on Recreational Vehicle Parks and Campgrounds, 2014 Ed. |
| NFPA 1600 | Standard on Disaster/Emergency Management and Business Continuity/Continuity of Operations Programs, 2016 Ed. |
| NFPA 1963 | Standard for Fire Hose Connections, 2014 Ed. |
| NFPA 2001 | Standard on Clean Agent Fire Extinguishing Systems, 2015 Ed. |

NFPA 2010 Standard for Fixed Aerosol Fire Extinguishing Systems, 2015 Ed.

§ 2. Amendments to the 2015 International Fire Code

- a. [Reserved]

§ 3. Amendments to the 2015 Life Safety Code (NFPA 101)

- a. [Reserved]

§ 4. Amendments to the 2015 Uniform Fire Code (NFPA 1)

- a. [Reserved]